



Annexure C

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

No:BBMP/MOH/MDP/PR/23/2025-26

Dated:05-06-2025

It is certified that an inspection team headed by DR. RAKESH.N MEDICAL OFFICER OF HEALTH (Name of Officers with designation) from BBMP HEALTH DEPARTMENT PHED inspected the VAGDEVI VILAS SUPER SCHOOL Sy No.76, Munnekolalu Marthahlli Post Bengaluru-560037 (Name & Address of the school) on 04-06-2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no ULR NO: TC96532500004359f F dated:12-05-2025 of EUREKA Analytical Services Pvt Ltd (PHED Lab)certified that the VAGDEVI VILAS SUPER SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central State U.T. Govt.  
This certificate is valid till :04-06-2026

*Jagdevi*  
Principal

**Vagdevi Vila: Super School**  
Sy. No. 76, Munnekolalu,  
Marathahalli, Bengaluru-560037

To  
VAGDEVI VILAS SUPER SCHOOL  
Sy.No.76, Munnekolalu  
Marthahlli Post Bengaluru-560037 (Name & Address of the Institution)

Signature with Seal: *Rakesh N*

Name : DR. RAKESH.N  
Designation : MEDICAL OFFICER OF HEALTH  
Name & Address of the Office : Department : BBMP

**ಆರೋಗ್ಯ ವ್ಯಾಪಾರಿಗಳ  
ಮಹದೇವಪುರ ವಲಯ**

**ಮೇಡಿಕಲ್ ಆಫೀಸರ್  
MEDICAL OFFICER OF HEALTH  
MADEVAPURA ZONE  
BENGALURU.**

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

**27 JUN 2025**



**ATTESTED BY ME**

*K.V. Jagannath Reddy*  
**K.V. JAGANNATH REDDY, B.A., L.L.B.**  
**ADVOCATE & NOTARY PUBLIC**  
**GOVT. OF INDIA**  
No. 274, 2nd Cross, Behind Tulas, Trunk Road, Bengaluru-560022

**Govt. Of Karnataka Notary**  
**Stamp Not Assigned**  
**Herce Not Affixed Stamp**  
*Sudharamma Krishnamurthy*  
**For Sudharamma Krishnamurthy**  
**Educational & Charitable Trust (Regd)**  
**(Managing Trustee)**



Annexure C

**FOR SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE**

No:BBMP/MOH/MDP/PR/23/2025-26

Dated:05-06-2025

It is certified that an inspection team headed by DR. RAKESH.N MEDICAL OFFICER OF HEALTH (Name of Officers with designation) from BBMP HEALTH DEPARTMENT PHED inspected the VAGDEVI VILAS SUPER SCHOOL Sy No.76, Munnekolalu Marthahlli Post Bengaluru-560037 (Name & Address of the school) on 04-06-2025 (date of inspection) and on the basis of Water Test Report (Attached) bearing no ULR NO: TC96532500004359f F dated:12-05-2025 of EUREKA Analytical Services Pvt Ltd (PHED Lab)certified that the VAGDEVI VILAS SUPER SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central State U.T. Govt.

This certificate is valid till :04-06-2026

Signature with Seal:

Name : DR. RAKESH.N

Designation : MEDICAL OFFICER OF HEALTH

Name & Address of the Office : Department : BBMP

**ಆರೋಗ್ಯ ವ್ಯಾಪಾರಿಗಳು**

**ಮಹದೇವಪುರ ವಲಯ**

**ಬೆಂಗಳೂರು**

16

VAGDEVI VILAS SUPER SCHOOL

Sy No.76, Munnekolalu

Marthahalli Post Bengaluru-560037 (Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

Principal

**Vagdevi Vilas Super School**

Sy. No. 76, Munnekolalu,  
Marathahalli, Bengaluru-560037

**For Sundaramma Krishnamurthy  
Educational & Charitable Trust (Regd)**

(Managing Trustee)

**VAGDEVI VILAS SUPER SCHOOL**

Sy. No. 76, Munnekolalu, Marathahalli Post,  
Bengaluru -560037



Scan for Scope



Scan for Authentication

## ANALYTICAL REPORT

Sample code: EKA1-25-05-01552

Sample Name: RO Water

Sample quantity: 5Ltr + 1Ltr x 2 nos

Sample Appearance: Clear Liquid

Condition on receipt: Good

Sample packing: Plastic can and PET Bottle

Environmental Condition: Not Applicable

Customer provided details: Not Applicable

Received On: 06/05/2025

Analysed between: 07/05/2025 to 09/05/2025

Sampling Details: Sampled By Eureka

Sampling Procedure: EKA-GEN-SOP-24

Sampling date: 06/05/2025

Sampling Location: Sy no 76 Munnekolalu

Marathahalli

Time of Sampling: 01:30 PM

Name of Laboratory Representative: A Swamy

### Test Results

S. No.	Test Parameter	Test method	Result	Unit	Acceptable Limits, max	Permissible Limits in Absence of an Alternate source, max
<b>Table: 1</b>						
<b>Organoleptic and Physical Parameters</b>						
1	Colour	IS 3025 (Part-4): 2021	<1	Hazen Units	5	15
2	Odor	IS 3025 (Part-5): 2008	Agreeable	-	Agreeable	Agreeable
3	pH	IS 3025 (Part-11): 1983	6.59	-	6.5-8.5	No relaxation
4	Taste	IS 3025 (Part-7): 1984	Agreeable	-	Agreeable	Agreeable
5	Turbidity	IS 3025 (Part-10): 1984	<1	NTU	1	5
6	Total Dissolved Solids	IS 3025 (Part-16): 1984	28	mg/l	500	2000
<b>Table: 02</b>						
<b>General Parameters Concerning Substances Undesirable in Excessive Amounts</b>						
7	Ammonia (as NH <sub>3</sub> N)	IS 3025 (Part-34): 1988	<0.3	mg/l	0.5	No relaxation
8	Anionic detergents (as MBAS)	IS 13428 Annex K: 2005	<0.1	mg/l	0.2	1
9	Calcium as Ca	IS 3025 (Part-40): 1991	5.61	mg/l	75	200
10	Chloramines as Cl <sub>2</sub>	IS 3025 (Part-26): 1986	<0.2	mg/l	4	No relaxation
11	Chloride as Cl	IS 3025 (Part-32): 1988	4.44	mg/l	250	1000
12	Fluoride as F	IS 3025 (Part-60): 2008	<1.0	mg/l	1	1.5
13	Residual Free Chlorine	IS 3025 (Part-26): 1986	<0.2	mg/l	0.2	1.0
14	Magnesium as Mg	IS 3025 (Part-46): 1994	<0.5	mg/l	30	100
15	Nitrate as NO <sub>3</sub>	IS 3025 (Part-34): 1988	1.261	mg/l	45	No relaxation
16	Phenolic Compounds	IS 3025 (Part-43): 1992	<0.001	mg/l	0.001	0.002
17	Sulphate as SO <sub>4</sub>	IS 3025 (Part-24): 2022	<1.0	mg/l	200	400

*Jayashree*  
Principal  
Vagdevi Vilas Super School  
Sy. No. 76, Munnekolalu  
Marathahalli, Bengaluru-560037

Eureka Analytical Services Pvt Ltd,

Plot No. 617, 5th Main, OMBR Layout, Kasturi Nagar main road, Banaswadi Bangalore-560043  
Email: info@eurekaserv.com, Website: www.eurekaserv.com, CIN: U73100KA2019PTC01732

For Sundaramma Krishnamurthy  
Educational & Charitable Trust (Regd)  
*(Managing Trustee)*

18	Sulphide as H <sub>2</sub> S	IS 3025 (Part-29): 1986	<0.05	mg/l	0.05	No relaxation
19	Total Alkalinity as CaCO <sub>3</sub>	IS 3025 (Part-23): 1986	20.10	mg/l	200	600
20	Total Hardness as CaCO <sub>3</sub>	IS 3025 (Part-21): 2009	16.01	mg/l	200	600
21	Aluminium as Al	IS 3025 (Part-65): 2019	<0.02	mg/l	0.03	0.2
22	Barium as Ba	IS 3025 (Part-65): 2019	<0.5	mg/l	0.7	No relaxation
23	Boron as B	IS 3025 (Part-65): 2019	<0.5	mg/l	0.5	2.4
24	Copper as Cu	IS 3025 (Part-65): 2019	<0.02	mg/l	0.05	1.5
25	Iron as Fe	IS 3025 (Part-65): 2019	<0.1	mg/l	1.0	No relaxation
26	Manganese as Mn	IS 3025 (Part-65): 2019	<0.02	mg/l	0.1	0.3
27	Selenium as Se	IS 3025 (Part-65): 2019	<0.001	mg/l	0.01	No relaxation
28	Silver as Ag	IS 3025 (Part-65): 2019	<0.01	mg/l	0.1	No relaxation
29	Zinc as Zn	IS 3025 (Part-65): 2019	<0.1	mg/l	5	15
30	Mineral Oil	IS 3025 (Part-39): 2021	<0.1	mg/l	1.0	No relaxation
31	Uranium	IS 3025 Part 65	0.003	mg/l	0.03	No relaxation

**Table 3**

**Parameters Concerning Toxic Substances**

32	Cyanide as CN	IS 3025 (Part-27): 1986	<0.01	mg/l	0.05	No relaxation
33	Cadmium as Cd	IS 3025 (Part-65): 2019	<0.001	mg/l	0.003	No relaxation
34	Lead as Pb	IS 3025 (Part-65): 2019	<0.001	mg/l	0.01	No relaxation
35	Mercury as Hg	IS 3025 (Part-65): 2019	<0.001	mg/l	0.001	No relaxation
36	Molybdenum as Mo	IS 3025 (Part-65): 2019	<0.02	mg/l	0.07	No relaxation
37	Nickel as Ni	IS 3025 (Part-65): 2019	<0.02	mg/l	0.02	No relaxation
38	Total Arsenic as As	IS 3025 (Part-65): 2019	<0.001	mg/l	0.01	No relaxation
39	Total Chromium as Cr	IS 3025 (Part-65): 2019	<0.02	mg/l	0.05	No relaxation

**PCB'S**

40	2,4,4'-Trichlorobiphenyl	EKA-CHE-SOP-68	<0.00001	mg/l	0.0005	No relaxation
41	2,2'3,4,4',5' Hexachlorobiphenyl		<0.00001	mg/l		
42	2,2'4,4',5,5' hexachlorobiphenyl		<0.00001	mg/l		
43	2,2',4,5,5'- Pentachlorobiphenyl		<0.00001	mg/l		
44	2,2',5,5'- Tetrachlorobiphenyl		<0.00001	mg/l		
45	2,3',4,4',5 - Pentachlorobiphenyl		<0.00001	mg/l		
46	2,2'3,4,4,5,5' -Heptachlorobiphenyl		<0.00001	mg/l		

**PAH'S**

47	Anthracene	EKA-CHE-SOP-68	<0.00001	mg/l	0.0001	No relaxation
48	Acenaphthene		<0.00001	mg/l		
49	Acenaphthylene		<0.00001	mg/l		
50	Benz[a]anthracene		<0.00001	mg/l		
51	Benzo[b]fluoranthene		<0.00001	mg/l		
52	Benzo(g,h,i) perylene		<0.00001	mg/l		
53	Benzo(k)fluoranthene		<0.00001	mg/l		
54	Dibenz(a,h)anthracene		<0.00001	mg/l		
55	Fluoranthene		<0.00001	mg/l		
56	Fluorene		<0.00001	mg/l		
57	Indeno(1,2,3-cd) Pyrene		<0.00001	mg/l		
58	Naphthalene		<0.00001	mg/l		
59	Phenanthrene	<0.00001	mg/l			

For Sundaramma Krishnamurthy Educational & Charitable Trust (Regd)

*(Signature)*  
(Managing Trustee)

**Eureka Analytical Services Pvt Ltd,**

AB Square, #617, 5th Main, OMBR Layout, Kasturi Nagar main road, Banaswadi Bangalore-560043

Email: info@eurekastrv.com, Website: www.eurekastrv.com, CIN: U73100KA2019PTC127732

*(Signature)*  
Principal  
Vagdevi Vilas  
Sy. No. 76, Mun...  
Marathahalli, Bengaluru-560035

60	Pyrene		<0.00001	mg/l		
61	Chrysene		<0.00001	mg/l		
62	Benzo(a)pyrene		<0.00001	mg/l		
<b>TRihalOMETHANES</b>						
63	Bromoform	EKA-CHE-SOP-68	<0.01	mg/l	0.1	No relaxation
64	Dibromochloromethane		<0.01	mg/l	0.1	No relaxation
65	Bromodichloromethane		<0.01	mg/l	0.06	No relaxation
66	Chloroform		<0.01	mg/l	0.2	No relaxation

**Table 5**

**Pesticide Residues Limits and Test Method**

67	Alachlor	EKA-CHE-SOP-68	<0.01	µg/l	20	No relaxation
68	Atrazine		<0.01	µg/l	2	No relaxation
69	Aldrin		<0.01	µg/l	0.03	No relaxation
70	Dieldrin		<0.01	µg/l		
71	Alpha HCH		<0.01	µg/l	0.01	No relaxation
72	Beta HCH		<0.01	µg/l	0.04	No relaxation
73	Butachlor		<0.01	µg/l	125	No relaxation
74	Chlorpyrifos		<0.01	µg/l	30	No relaxation
75	Delta HCH		<0.01	µg/l	0.04	No relaxation
76	2,4-Dichlorophenoxyacetic acid		<0.01	µg/l	30	No relaxation
77	2,4 DDT		<0.01	µg/l	1	No relaxation
78	4,4 DDT		<0.01	µg/l		
79	2,4 DDE		<0.01	µg/l		
80	4,4, DDE		<0.01	µg/l		
81	2,4 DDD		<0.01	µg/l		
82	4,4 DDD		<0.01	µg/l	0.4	No relaxation
83	Endosulfan alpha		<0.01	µg/l		
84	Endosulfan beta		<0.01	µg/l		
85	Endosulfan sulphate		<0.01	µg/l	3	No relaxation
86	Ethion		<0.01	µg/l		
87	Gamma — HCH (Lindane)		<0.01	µg/l	2	No relaxation
88	Isoproturon		<0.01	µg/l	9	No relaxation
89	Malathion	<0.01	µg/l	190	No relaxation	
90	Methyl parathion	<0.01	µg/l	0.3	No relaxation	
91	Monocrotophos	<0.01	µg/l	1	No relaxation	
92	Phorate	<0.01	µg/l	2	No relaxation	

**Table 6**

**Bacteriological Quality of Drinking water**

93	<i>E. Coli</i>	IS 15185:2016	Absent	/100ml	Shall not be detected in any 100ml sample	Shall not be detected in any 100ml sample
94	<i>Coliform</i>		Absent	/100ml	Shall not be detected in any 100ml sample	Shall not be detected in any 100ml sample

*Jayshree*  
Principal  
**Vagdevi Vilas Super School**  
Sy. No. 76, Munnekolalu,  
Marathiahalli, Bengaluru-560037

For Sundaramma Krishnamurthy  
Educational & Charitable Trust (Regd)

*[Signature]*  
Managing Trustee

**Eureka Analytical Services Pvt Ltd,**

3rd Square, #617, 5th Main, OMBR Layout, Kasturi Nagar main road, Banaswadi Bangalore-560043  
Email: info@eurekaserv.com, Website: www.eurekaserv.com, CIN: U73100KA2019PTC127732

EUREKA



Member of **GBA** GROUP

Report code: TR-25-EKA1-043593-01

Report Date: 12/05/2025

ULR no.: TC965325000043593F

BLQ: Below Limit of Quantification.

LOQ: Limit of Quantification for - (PCB'S & PAH's - 0.00001 mg/l), (Trihalomethanes - 0.01 mg/l) & (Pesticides - 0.01 µg/l)

Max. = Maximum

Min. = Minimum

NA: Not Applicable.

BDL is the below Detection limit of the detector.

# - Residual Free Chlorine <0.2 mg/L (Analyzed at lab) Sample is not chlorinated.

**Sample Remark /Conclusion:** The analysed sample conforms to IS 10500: 2012 RA 2023 (Drinking water specification) including all amendments in its current and valid version.

Note: Conclusion is provided with reference to tested analytes only.

Mr Varaprasad A Babu  
Authorised Signatory  
Chemical

Dr. Bharath M R  
Authorised Signatory  
Biological

The results may not be reproduced except in full, without written approval from laboratory. The results relate only to the above analysed sample.

Note: Any modification or editing in any manner, of a test report issued by Eureka is not permitted and is illegal. Eureka retains the right to proceed with legal action against the concerned in case of any such instance coming to light.

\*\*\*\*\* END OF REPORT \*\*\*\*\*

Principal  
**Vagdevi Vilas Super School**  
Sy. No. 76, Munnekolalu,  
Marathahalli, Bengaluru-560037

For Sundaramma Krishnamurthy  
Educational & Charitable Trust (Regd)

  
(Managing Trustee)

**Eureka Analytical Services Pvt Ltd,**

AB Square, #617, 5th Main, OMBR Layout, Kasturi Nagar main road, Banaswadi Bangalore-560043  
Email: info@eurekaserv.com, Website: www.eurekaserv.com, CIN: U73100KA2019PTC127732